



Legislation Text

File #: 2019-0241, **Version:** 1

Consider a resolution authorizing the City Manager to issue a Purchase Order to Precision Pump Systems for the purchase of two (2) Pumps at the East Wastewater Treatment Plant.

Multiple pump failures at the East Wastewater Treatment Plant (WWTP) lift station has lead to the need for purchasing two new 139 hp Sulzer pumps. One of the pumps was under warranty, and the other would have cost \$85,000 to repair. The better option is to purchase two brand new pumps with 5-year warranties, for \$97,000.

This will be a shared cost of the BCRWWS partner cities. The City's portion is 81.96% based on reserved capacity in the system.

Cost: \$97,000.00

Source of Funds: Regional Wastewater Fund